

## Report of Materials and <sup>a</sup> Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Robert D. LiMandri, Acting Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 304-89-M Vol. 5

Manufacturer:	RIF International Corporation 3875 Embassy Parkway Fairlawn, Ohio 44333
Trade Name(s):	Koroseal, Vicrtex, Sanitas, RJF, Korographics
Product:	Medium-weight vinyl-coated wallcovering MEA Index #440-320 – Wall Covering
Pertinent Code Section(s):	27-348
Prescribed Test(s):	RS 5-5 (ASTM E84), Toxicity
Laboratory:	Underwriters Laboratories, Inc. (UL) and US Testing Co.
Test Report(s):	UL File #4616 dated November 16, 1992 and September 9, 1994. US Testing #062117-1A dated November 27, 1989.

**Description:** Medium-weight vinyl-coated wallcovering having a maximum finished weight of 20.6 ounces per yard square. The wallcovering is manufactured by RJF International Corporation and is being marketed under the trade names of Korseal, Sanitas, Vicrtex, RJF and Korographics.

Flame Spread Rating: 15 Smoke Developed Rating: 20 **Terms and Conditions:** The above-described wallcovering material, as having interior finish Class 'A' with flame spread and smoke developed ratings as indicated above, is accepted with the following conditions:

- 1. Upon exposure to fire, the material does not produce products of decomposition or combustion that are more toxic than those given off by wood when decomposing or burning under comparable conditions.
- 2. All shipments and deliveries of such material shall be provided with a certificate or label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance September 17, 2008

Examined By Suco Derphydam