

CERTIFICATIONS CE  
DECLARATION OF  
PERFORMANCE



Koroseal Interior Products, LLC  
7929 National Tpke Louisville, KY 40218

Trading As: **Koroseal & Korographics**

In compliance with Regulation 305/2011/EU of the European Parliament and the Council of 9 March 2011 (The Construction Products Regulation or CPR), we do hereby declare that the CE marked products specified in Table 1 conform to the product performance requirements of annex ZA in the product standard:

**EN 15102:2007 +A1:2011**  
**Decorative Wallcoverings - Roll and Panel Form**

Table 1

Construction Product Description:	Report No.	Reaction to Fire:
Decorative Type I vinyl wallcovering on woven and non-woven backing, FR treated. Total mass: 339 g/m <sup>2</sup> to 407 g/m <sup>2</sup>	Reaction to fire classification DO-22-4407_A-R1 DO-22-4407_B-R1	C -s2, d0
Decorative Type II and Type III vinyl wallcovering on woven and non-woven backing, FR treated. Total mass: 451 g/m <sup>2</sup> to 790 g/m <sup>2</sup>	Reaction to fire classification DO-22-4407_E-R1 DO-22-4407_D-R1 DO-23-4527_A-R1 DO-23-4783_A/B/C-R1	B -s2, d0
Decorative Type II TPO wallcovering on non-woven backing, Fr Treated Total mass: 383 g/m <sup>2</sup>	Reaction to fire classification DO-22-4410_A-R1	C -s1, d0
Other requirements:	Release of Heavy metals and specific elements	Pass
Release of Formaldehyde – (< 120mg/Kg)	-	-
Release of Vinyl Chloride Monomer – Pass (< 0.2mg/Kg)		
Sound Absorption – No performance determined		
Thermal Resistance – No performance determined		
	Heavy Metal	Specification
	Antimony	No upper limit
	Arsenic	< 25 mg/Kg
	Barium	< 500 mg/Kg
	Cadmium	< 25 mg/Kg
	Chromium	< 60 mg/Kg
	Mercury	< 20 mg/Kg
	Lead	< 90 mg/Kg
	Selenium	< 165 mg/Kg
	Test Report: Centexbel: 22.06158.01	
Intended Use: Hanging on to internal walls, or partitions, by means of adhesive for the primary purpose of decoration.		
AVCP: System 1		
Notified Certification Body: CENTEXBEL – No. 0493		

Signed:  
Name: Joe Thompson

Position: Sr. Technical Manager  
Date: April 1, 2023